

Request for Selection of System Integrator for Supplying Installation Testing Commissioning of Smart LED based Street Lighting System with Retrofitting of Existing System and operational and Maintenance for 5 years at Dharamshala

CORRIGENDUM No.3

Tender ID: 2021_DSCL1_43653_1 dated 11.01.2021

Corrigendum Date: 12/03/2021

File No. - DSCL/Smart Street Lighting System/108/2020 - 2407

DSCL has issued the following corrigendum for RFP no. - DSCL/11/2020 for Request for Selection of System Integrator for Supplying Installation Testing Commissioning of Smart LED based Street Lighting System with Retrofitting of Existing System and operational and Maintenance for 5 years at Dharamshala).

Sl. No.	Clause No.	Page/Item No.	Content as per Request for Proposal (RFP)	Clarification
1	Clause no 16 (Bill of Quantities)	BOQ item no-18 and S.no-18 of section 16 of RFP vol-II (Page.no 159)	Providing, laying and fixing of PVC insulated flexible power cable, working voltage 1100 volts grade on surface etc. of the required size, including suitable size of jointing Kits and aluminum lugs.- 3- Core 6 Sq.mm flexible cable for single phase power supply .	Providing, laying and fixing of PVC insulated copper flexible power cable, working voltage 1100 volts grade on surface etc. of the required size, including suitable size of jointing Kits and Copper lugs. :- 3- Core 6 Sq.mm flexible cable for single phase power supply.


MD-cum-CEO
Dharamshala Smart City Ltd
12.03.2021