

Project

Dt. 06.08.18

Solar Roof PV Plants (AP 16.1)

CLARIFICATIONS

To

PRE-BID QUERIES

Sr No	Query	Clause	Amendment
1	PV modules must be tested and approved by one of the IEC authorized test centers. Lab reports not later than 1 year shall be accepted as a concept of Proof of testing.	2.4.5	PV modules must be tested and approved by one of the IEC authorized test centers. Lab reports not later than 3 year shall be accepted as a concept of Proof of testing.
2	The PBG shall be valid up to 90 days beyond the completion of the Operation and Maintenance period.	1.6 (f)	PBG (10% of total contract value) shall be valid upto 90 days beyond the installation and commissioning date which will be returned on replacing it with a PBG for an amount of 20% of the remaining payable amount which will be revised every year
3	The bidder must take care of approval through DSCL (DSCL)	2.16.1	Transformers (if required) shall be in

[Handwritten mark]

[Handwritten signature]

	from concerned HPSLB for the connectivity, technical feasibility, transformers (if need to be installed) and synchronization for evacuation of power from Solar PV power plant and submit the same document before commissioning of Solar PV plant.		scope of authority
4	The Sole Bidder or Member of consortium should have average annual Turnover of Rs. 3 Crore for last 3 audited financial years.	1.4.5	The Sole Bidder or the Lead Member of consortium should have average annual Turnover of Rs. 3 Crore for last 3 audited financial years.
5	Location wise variation is allowed	Annexure I	Yes, Location wise variation is allowed. However; Such variation shall be approved by authority
6	The Bidder shall quote only one specific make and model from only one specific OEM, for each of the goods. Providing more than one option shall not be allowed.	1.4.6	One OEM for one product shall be given. Eg: all inverters shall be of one make, all solar PV Modules will be of single make only. Multiple brands will not be allowed for single product for the project
7	Fire Extinguishers	2.19	Proving safety equipments shall be in Bidder scope of work
8	Warranty on all components shall	2.4.10	Warranty on inverter shall be 5 years or

18

18

	be 5 years		more. Warranty on solar PV modules shall be more than 20 years. Warranty on all other components shall be 2 years or more
9	Insurance	1.9	Insurance shall be comprehensive and in joint name of bidder and authority
10	General requirement of maintenance	2.25	The maintenance for 5 years refer to the all the required repair, maintenance & replacement of (any) part(s) during the O&M duration for smooth running of all the items mentioned.

Law
Solar Expert
PMC

CP
GM (PAC)
DSCL